

Classification of Data Center Infrastructure Management (DCIM) Tools

White Paper 104

Revision 3

by Kevin Brown
Dennis Bouley

> Executive summary

Data centers today lack a formal system for classifying infrastructure management tools. As a result, confusion exists regarding which management systems are necessary and which are optional for secure and efficient data center operation. This paper divides the realm of data center management tools into four distinct subsets and compares the primary and secondary functions of key subsystems within these subsets. With a classification system in place, data center professionals can begin to determine which physical infrastructure management tools they need – and don't need – to operate their data centers.

Contents

Click on a section to jump to it

Introduction	2
Classification system context	3
Monitoring & Automation	4
Planning & Implementation	8
Data collection	11
Dashboard	11
Conclusion	13
Resources	14
Appendix	15

Introduction

The total data center universe that most data center professionals are familiar with principally consists of two realms. The first realm, information technology (IT), refers to all systems that address the information processing aspects of the data center (e.g., servers, storage arrays and network switches). The second realm revolves around the physical infrastructure and controls that allow the IT realm to function. This second realm includes the physical infrastructure systems that support both the IT (“white space”) realm of the data center as well as the larger data center facility itself. This would include facility power, cooling and security systems. **The management classification system described in this paper is limited in scope to the physical infrastructure of the data center facility and IT areas.**

Both realms are interrelated but the subsystems within each are procured, managed, and maintained by separate users. Typically, facilities and engineering departments “own” and operate facility and IT infrastructure systems. IT department personnel “own” the IT equipment. In some larger data centers both IT and infrastructure devices share a common communications backbone. As the total data center evolves, these departments will become more intertwined as will the management systems that support them. **Table 1** provides definitions of terms utilized in this paper to describe and contrast the data center infrastructure management classification system.

Term	Definition	Data Center Examples
Facility & IT infrastructure	This represents the totality of the material systems and foundational physical equipment necessary to facilitate operations of a reliable, controlled and secured IT environment.	<ul style="list-style-type: none"> • Power systems • Cooling systems • Security systems
Information Technology (IT)	The entire spectrum of technologies for information processing, including software, hardware, communications technologies and related services.	<ul style="list-style-type: none"> • Servers • Storage systems • Network systems
Environment	The total physical surroundings within a building or facility that house the various pockets of data center related hardware and software.	<ul style="list-style-type: none"> • IT room • Electrical room • Mechanical room
Subset	A logical grouping of physical subsystems with similar primary functions (four of these).	<ul style="list-style-type: none"> • Monitoring & Automation • Planning & Implementation • Dashboard • Data Collection
Subsystem	A purpose-built software package that addresses a specific need (potentially hundreds of these).	<ul style="list-style-type: none"> • Facility power device monitoring subsystem • IT room security monitoring subsystem
Primary function	A software function that is first in order of development and first in rank or importance when compared to other software functions available within that particular subsystem.	<ul style="list-style-type: none"> • The PowerLogic ION Enterprise software package’s electrical room power analytics function
Secondary function	A software function that is second in rank of importance or later in order of development coming after the primary function.	<ul style="list-style-type: none"> • The PowerLogic ION Enterprise software package’s facility HVAC cooling device monitoring function

Table 1
Terminology definitions and examples

> A note regarding energy management

The data center infrastructure management context map as presented in **Figure 1** does not specifically call out energy management in any of its subsets. In fact energy management is involved throughout all layers of the management software construct and is not concentrated in any one subset or subsystem.

In an ideal world, data center managers should be able to run one management software package that addresses all of their basic needs. However, the concept of “one system” does not exist in any practical sense. While numerous vendors promise a vision of the ultimate “unified” management system, this has been an elusive dream that will be difficult to realize. The following points illustrate why “one system” is an unlikely goal in the foreseeable future:


- **A need for simple tools that fulfill specific requirements** – IT and facilities employees have different priorities and no one package will meet all of their needs. These employees prefer simple tools that focus on addressing their specific need.
- **Investments in pre-existing systems** - Most data center professionals already have software in place that performs part of the management function. In many cases, it is neither feasible nor cost effective to replace existing software.
- **Open protocols enable integration of disparate software** – Facility and IT infrastructure management software is highly specialized. However, when these tools are based on standardized, open protocols, it becomes quite easy to add new software tools, as needed, to an existing tool set and have them communicate and work together effectively. This capability, therefore, diminishes the demand or need for a single, unified system that covers everything.

Classification system context

Figure 1 illustrates a context map of the four subsets within the facility and IT infrastructure portion of the data center. Depending upon the size of a given data center, the total data center (i.e., both realms described above) could consist of hundreds of management software subsystems. The first step when classifying these subsystems is to group them into general subsets. Although the focus of this paper is facility and IT infrastructure management software, the subsets can also be used to classify IT management software.

Figure 1

This data center facility and IT infrastructure software context map demonstrates how the various subsets interact



Note that the subsets in **Figure 1** have either graphical user interfaces (GUI) or human machine interfaces (HMI) associated with them. Also note that the Dashboard subset is the primary area within the context map that allows for the visualization of *cross subset* information.

The first step for data center operators who are evaluating their management software is to examine key data center infrastructure systems such as the power distribution system, building mechanical and cooling facilities, IT room, and security. This will help to determine which subsystem management tools are already in place and, looking forward, which subsystem tools are actually needed. A colocation data center, for example, may not require a subsystem that manages at the IT room level. However, HVAC control and power management subsystems may be essential for that same colocation facility. A small or medium-sized data center with an IT room housing 100 racks might forgo a facility control and power management subsystem, leaving that to the facilities staff. However, the IT staff may wish to directly monitor performance data by investing in an IT room management subsystem.

Monitoring & Automation

Subsystems grouped within the Monitoring & Automation subset ensure that 1) the data center functions as designed, and 2), activities are automated to maintain / maximize the availability and efficiency of the data center. Monitoring & Automation software acts upon user-set thresholds by alarming, logging, or even controlling physical devices. The Monitoring & Automation subset of subsystems includes facility power, facility environmental control, facility security subsystems, and IT room management (see **Figure 2**). **Table 2** helps to differentiate the mainstream Monitoring & Automation subsystems in terms of their primary and secondary functions (see side bar “Not all monitoring solutions are created equal”).




Figure 2

The Monitoring & Automation subset contains several sub-systems each of which provide a number of functions


Four sub-system groupings exist within the Monitoring & Automation subset:

Facility power

The facility power management subsystem provides detailed insight into the status and operation of the entire electrical distribution network (from utility feeds, to transformers, to PDUs, to racks) within a building, often including the data center. Electrical engineering staff and consultants utilize this subsystem to manage the electrical distribution network. The key functions provided by this type of subsystem include power monitoring of current conditions (critical and non-critical load), power alarming, and “power analytics”. These functions support critical activities such as notification of and response to electrical network problems, maintenance (planned and unplanned), capacity planning, facility expansion / retro-fit projects, energy efficiency projects, power quality analysis, and power reliability analysis.

Figure 3

Monitoring of facility power utilizing Schneider Electric's StruxureWare Power Monitoring Expert GUI



> Not all monitoring software solutions are created equal

Monitoring subsystems are built with a **primary function** in mind. Schneider Electric's StruxureWare Central IT room monitoring system, for example, has as its primary function the ability to monitor power and cooling in the IT room. However, many monitoring systems expand their capabilities over time.

These **secondary functions** are typically less robust than those found in a purpose-built system. StruxureWare Central, for example, has a secondary ability to monitor Modbus devices outside the IT room. While not its primary function, that ability may be enough for data center operators with simple Modbus device monitoring requirements. **Table 2** shows examples of the primary and secondary functions of physical infrastructure monitoring systems.

The facility power management subsystem offers a clear and complete view of facility power distribution. Also provided is actionable information based on detailed electrical data such as power, energy, power factor, amperage, voltage, frequency, harmonics, and waveforms. The subsystem's output includes 3-D graphical views of the facility, electrical one-lines, and equipment detail. The facility power management subsystem also provides visual alarm indicators and alarm notification, data analysis tools, and the ability to schedule and distribute reports.

Facility power management subsystems can either provide a fairly simple, primary electrical monitoring function for smaller data centers, or can provide extremely high speed and high performance feedback for large sites. Schneider Electric's StruxureWare Power Monitoring Expert is an example of a facility power monitoring subsystem (see **Figure 3**).

Facility environmental control

Facility environmental control subsystems traditionally support the requirements of corporate facilities departments. In addition to facility heat, ventilation, and air conditioning (HVAC) control, facility environmental subsystems can also encompass fire systems, water, steam, and gas systems. The preferred communication protocols for facility environmental control systems include BACnet, LONworks, and Modbus.

Everyday functions of facility environmental control systems include the opening and closing of valves and dampers, the spinning up fans, initialization of pumps, and the controlled cooling and heating of targeted spaces within the facility.

Schneider Electric's StruxureWare Building Expert is an example of a mainstream facility environmental control subsystem. Facility environmental control subsystems are also differentiated from facility power management subsystems in that facility environmental control handles the coordination, control and reporting for all energies, not just electrical power.

Table 2

Comparison of Monitoring & Automation primary and secondary functions using Schneider Electric's StruxureWare for Data Centers suite as an example

	Data Center Expert*	Power Monitoring Expert**	Building Expert (BMS)	Pelco Digital Sentry
Facility Power				
Power device monitoring	Secondary Function	Primary function	Secondary Function	No Function
Power analytics	No Function	Primary function	No Function	No Function
PUE monitoring	Secondary Function	Secondary Function	Primary function	No Function
Facility Environmental Control				
Automation and control	No Function	No Function	Primary function	No Function
Cooling device monitoring	Secondary Function	Secondary Function	Primary function	No Function
Facility Security				
Surveillance	Secondary Function	No Function	Secondary Function	Primary function
Access control	No Function	No Function	Secondary Function	No Function
IT Room				
Power device monitoring	Primary function	Primary function	Secondary Function	No Function
Cooling device monitoring	Primary function	No Function	Secondary Function	No Function
Environmental monitoring	Primary function	No Function	Secondary Function	No Function
Security monitoring	Primary function	No Function	Secondary Function	Secondary Function
Partial PUE monitoring	Secondary Function	Secondary Function	Secondary Function	No Function

FUNCTIONS

> Note regarding tables 2 and 3

Many physical infrastructure software products from multiple manufacturers exist in the marketplace today. Most offer a wide variety of functions. **Tables 2 and 3** compare the functions of only a partial sampling of the Schneider Electric products that fit within the Operations Technology (OT) universe.

Tables 2 and 3 are not meant to be a comprehensive representation of what is available in the marketplace. In fact, it is not Schneider Electric's role to represent other manufacturer's products in these tables. The functions of other manufacturer's products are often in a state of flux and could easily be misrepresented. Therefore these tables are restricted to a portion of the Schneider Electric current suite of products.

Generic tables are located in the **Appendix** which allow for data center operators to enter their own personal suite of management software products for comparison purposes.

Facility power devices include: breakers, trip units, medium voltage and low voltage metering (i.e., transformers, switches), programmable logic controllers (PLCs), remote terminal units (RTUs), automatic transfer switches (ATS), generator controls, UPS controls.

IT power devices include: UPS controls, power distribution units (PDUs) and branch circuit metering, rack power strip metering

* Includes security add-ons such as NetBotz, and PUE monitoring tools such as StruxureWare Data Center Operation : Energy Efficiency


** Works in coordination with installed meters for data collection

Facility security

As new technologies such as advanced optical video management systems, biometric identification, and remote management systems become more widely available, traditional card-and-guard security is being supplanted by facility security subsystems that can provide positive identification and tracking of human activity in and around the data center. Identification technology is changing as fast as the facilities, information, and communication it protects. Schneider Electric Pelco is an example of a facility security subsystem capable of providing both indoor and outdoor video security support.

Figure 4

Typical data center IT room security interface



> A note regarding subsystem users

Subsystems throughout the data center are managed by individuals with differing job responsibilities. On the IT side, operators tend to focus on a series of individual subsystem GUIs whereas management focuses on the consolidated information reported on the dashboard.

On the facilities side, a similar situation occurs. Engineers monitor individual building HVAC systems, for example, and the facilities management tends to interact with the dashboards that display cross facility information.

IT room

IT room management subsystems monitor the power and cooling systems on the IT room floor so that uptime of servers, communication equipment, and storage equipment can be maintained. Data center IT room management subsystems are developed around the needs and requirements of the computer room operators (a need for faster speed and real-time information). The IT environment is characterized by frequent changes, intelligent devices, and a management philosophy based on exception. These subsystems can also integrate with security cameras within rows of racks such as Schneider Electric’s NetBotz cameras.

IT room management subsystems are designed to accommodate simultaneous firmware upgrades to multiple systems, and to monitor battery health by identifying exceptions that indicate behavioral characteristics beyond pre-programmed thresholds. IT room management subsystems are built around the expectation that power and cooling monitoring operates in a manner similar to other IT applications. That is, the software can be self

installed, and the software performs auto discovery of linked components. In essence, everything just “works” out of the box, with the ability to change the configuration. These subsystems generally utilize an IP network communication protocol. Schneider Electric’s StruxureWare Data Center Expert is an example of an IT room management subsystem.

Planning & Implementation

Planning & Implementation, the second subset of subsystems (see **Figure 1**), ensures 1) efficient deployment of new equipment, 2) execution of planning in order to facilitate changes in the data center, 3) tracking of assets within the data center, and 4) simulation of potential changes in order to analyze the future impact on the data center. Functions within Planning & Implementation involve prediction and modeling (“What happens if I do this?”), change tracking (“At what point does my system get obsolete?”), inventory tracking (“How do I track the history and movements of this piece of equipment?”), and dependency analysis (“If I change the contents of this rack, how will it impact my cooling?”).


Five subsystem groupings exist within the Planning & Implementation subset:

Facility asset management – This subsystem allows for management of asset deployment, generation of facility-related parts specifications, calibration, costing and tracking of building equipment assets.

Facility capacity management – This subsystem aids facilities staff to plan both moves and changes within the mechanical and electrical rooms, by providing real-time measurements of energy consumption and water flows in addition to the project impact of changes to the power and cooling infrastructure.

Figure 5

The Planning & Implementation subset contains several sub-systems each of which provide a number of functions



IT room workflow management – This subsystem facilitates the execution of equipment additions, moves, and changes by presenting a hierarchical overview of data center locations, including global and local views and from groups to single assets.


 Link to resource
White Paper 150
Power and Cooling Capacity Management for Data Centers

IT room capacity management – From a power consumption efficiency perspective, the system identifies the optimal physical location for power, cooling, and rack-based IT equipment. User defined requirements such as redundancy, network use, and line of business groupings are also factored in. Live data is utilized to create simulations which analyze the impact of changes before they occur. This level of planning allows for reductions in stranded cooling and power capacity. For more information on the subject of stranded capacity, please see White Paper 150, *Power and Cooling Capacity Management for Data Centers*.

IT room asset & lifecycle management – This subsystem allows for the management of IT room inventory. Visual models of the data center layout enable tracking of IT assets and available space. The rendering of the data center physical layout also allows for visualization of power consumption per rack as well as identification and location of power failures.

Figure 6
Planning & Implementation for the IT room environment utilizing the Schneider Electric StruxureWare Data Center Operation GUI




Table 3 helps to differentiate some of the mainstream planning and implementation subsystems in terms of their primary and secondary functions.

		Power Monitor- ing Expert	Building Expert (BMS)	Data Center Operation	Data Center Operation - Capacity	Data Center Operation - Change	
FUNCTIONS	FACILITY ASSET MANAGEMENT						
	Inventory tracking	○	○	◐	○	○	
	Maintenance tracking	◐	◐	○	○	○	
	FACILITY CAPACITY MANAGEMENT						
	Impact and dependency analysis - Power	◐	○	◐	◐	○	
	Impact and dependency analysis - Cooling	○	◐	◐	◐	○	
	IT ROOM WORKFLOW MANAGEMENT						
	Prediction and modeling	○	○	○	●	○	
	Workflow tracking	○	○	○	○	●	
	IT ROOM CAPACITY MANAGEMENT						
	Impact and dependency analysis - Power	○	○	○	●	○	
	Impact and dependency analysis - Cooling	○	○	○	●	○	
	Impact and dependency analysis - Network	○	○	○	●	○	
	IT ROOM ASSET & LIFECYCLE MANAGEMENT						
	Inventory tracking	○	○	●	○	○	
	Change tracking	○	○	○	○	●	

Table 3

Comparison of Planning & Implementation primary and secondary functions using Schneider Electric's StruxureWare for Data Centers suite as an example

Data collection

The data collection subset represents devices such as meters, power protection devices, embedded cards, programmable logic controllers (PLCs), sensors and other such devices. These devices perform the fundamental function of gathering data and forwarding it to management software for processing.

Figure 7

Human machine interface (HMI) provides configuration and operation information for individual UPS device



Dashboard

Data center managers all require some means for consolidating critical information about the performance of their data center. Not only does the critical information need to be aggregated, but the user needs to visualize the data in a manner that is meaningful and actionable. In fact, this **visualization** of the data via a dashboard is a key function that allows a view across the four main subsystem subsets.

Operational dashboard data may include the following: average temperature and humidity, high temperature and humidity for a determined period, IT load, total data center load, and a summary of the last 10 critical alerts. From a security perspective the dashboard could also highlight the last 10 physical entries into the data center and the times when these entries took place. Some operators, who are responsible for controlling their own energy costs, may also require PUE data on their dashboard.

Some data center operators may choose to access data in its raw form without the benefit of a dashboard. For example, queries from SQL tables may be generated and transferred to an Excel file so that a report can be produced that meets the immediate requirement for performance information. Various monitoring subsystems can also highlight urgent issues. But as data centers become more complex, the information required needs to be easily formatted and presented into a formal dashboard. A dashboard represents a third subset which captures data from the three other subsets and then updates to a management package, providing KPIs and data summaries, over the existing network.

Some dashboards are more focused on the performance of the IT equipment while others provide summary views into the physical infrastructure (cooling, power, security). Dashboards draw their information from monitoring & automation and planning & implementation,


and data collection subsets. Some dashboards are custom built or are purchased from third parties (see **Figure 8** for sample dashboard).

Visualization software

Although the dashboard is the key centerpiece for aggregation of actionable data, various levels of human machine interface (HMI) and graphical user interface (GUI) exist and enable meaningful data to be visualized by specific users via the various subsystems across the data center (see GUI and HMI in **Figure 1**). Although the HMI used by the facilities engineer may not resemble the GUI utilized by the IT operator, both extract information from the system based upon the individual user’s preferences and priorities.

Figure 8

Sample dashboard collects data across OT subsets and centralizes information in one or more user interfaces



Conclusion

By sharing key data points, alarm notifications, historical data, and asset tracking information, data center facility and IT infrastructure management software allows users to make informed decisions based upon real-time power and cooling capacity and redundancy data.

The classification system presented in this paper takes the first step in laying the groundwork for a logical approach which can be summarized as follows:

A **Whole Data Center**, from which is selected the

Facility and IT infrastructure portion, which is divided into

Subsets, each of which consists of multiple

Subsystems, which are compared and contrasted by illustrating

Primary and Secondary functions, which enable

Efficient investment in management software

...with key steps supported by **visualization** software

Today multiple management applications across the principle domains of IT room management, building control, security, and power address various parts of the enterprise suite, but no one application does it all. The segmented approach will continue for the foreseeable future. However, innovative dashboards are being developed that will facilitate prudent, informed operational decisions that consolidate information from these sources and enhance uptime and reduce energy costs.



About the author

Kevin Brown is the Vice President of Data Center Global Solution Offer & Strategy at Schneider Electric. Kevin holds a BS in mechanical engineering from Cornell University. Prior to this position at Schneider Electric, Kevin served as Director of Market Development at Airxchange, a manufacturer of energy recovery ventilation products and components in the HVAC industry. Before joining Airxchange, Kevin held numerous senior management roles at Schneider Electric, including Director, Software Development Group.

Dennis Bouley is a Senior Research Analyst at Schneider Electric's Data Center Science Center. He holds bachelor's degrees in journalism and French from the University of Rhode Island and holds the Certificat Annuel from the Sorbonne in Paris, France. He has published multiple articles in global journals focused on data center IT and physical infrastructure environments and has authored several white papers for The Green Grid.



Resources

Click on icon to link to resource



Power and Cooling Capacity Management for Data Centers

White Paper 150



Browse all white papers

whitepapers.apc.com



Browse all TradeOff Tools™

tools.apc.com



Contact us

For feedback and comments about the content of this white paper:

Data Center Science Center
DCSC@Schneider-Electric.com




















































If you are a customer and have questions specific to your data center project:

Contact your **Schneider Electric** representative at
www.apc.com/support/contact/index.cfm

Appendix

Table A1

*Monitoring & Automation
product comparison worksheet*

		 Primary function  Secondary Function  No Function				Data Center Expert*	Power Monitoring Expert**	Building Expert (BMS)	Pelco Digital Sentry	Name of product:	Name of product:	Name of product:	Name of product:	Name of product:
FUNCTIONS	FACILITY POWER													
	Power device monitoring													
	Power analytics													
	Efficiency monitoring													
	FACILITY ENVIRONMENTAL CONTROL													
	Cooling device monitoring													
	Automation and control													
	FACILITY SECURITY													
	Surveillance													
	Access control													
	IT ROOM													
	Power device monitoring													
	Cooling device monitoring													
	Environmental monitoring													
	Security monitoring													
Partial PUE monitoring														

* Includes security add-ons such as NetBotz, and PUE monitoring tools such as InfraStruxure Energy Efficiency

** Works in coordination with installed meters for data collection

Table A2

*Planning & Implementation
product comparison worksheet*

		Power Monitor- ing Expert	Building Expert (BMS)	Data Center Operation	Data Center Operation - Capacity	Data Center Operation - Change	Name of product	Name of product	Name of product	Name of product
FUNCTIONS	FACILITY ASSET MANAGEMENT									
	Inventory tracking	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>				
	Maintenance tracking	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>				
	FACILITY CAPACITY MANAGEMENT									
	Impact and dependency analysis - Power	<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				
	Impact dependency analysis - Cooling	<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				
	IT ROOM WORKFLOW MANAGEMENT									
	Prediction and modeling	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				
	Workflow tracking	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>				
	IT ROOM CAPACITY MANAGEMENT									
	Impact and dependency analysis - Power	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				
	Impact and dependency analysis - Cooling	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				
	Impact and dependency analysis - Network ports	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>				
	IT ROOM ASSET & LIFECYCLE MANAGEMENT									
	Inventory tracking	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>				
	Change tracking	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>				